

ATHENA POWER

Detroit Edison Sensor Pilot
Data Analysis 2023 (First Half)




ATHENA-POWER.COM INFO@ATHENA-POWER.COM 512.913.4919

Data Analysis 2023


ATHENA-POWER.COM

Sensor Daily Count / Collection


DTE1 Hourly




DTE5 Hourly



DTE4 Hourly



DTE6 Hourly




Day of Collection Time
January 1, 2023 to June ..

Data Analysis

- 1) All UFD Sensors provided rich data counts with minimal gaps in data generation and acquisition
- 2) DTE 1 maintained a flat trend-line with reasonable variations in Frequency
- 3) DTE 4, 5, and 6 had trending up & down Frequency

DTE1 Hourly





Data Analysis

- 1) DTE 1 maintained a flat trend-line with reasonable variations in Frequency

The plots of count of DTE 1.csv and average of Frequency(Hz) for Collection Time Day. The data is filtered on Collection Time, which ranges from 1/6/2023 12:00:00 AM to 6/29/2023 11:53:12 PM. The view is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023.

DTE4 Hourly




Data Analysis

- 1) DTE 4 is displaying a downward trend in Frequency
- 2) Further assessment is suggested for this issue

The plots of count of DTE 4.csv and average of Frequency(Hz) for Collection Time Day. The data is filtered on Collection Time (DTE 1) Day, which ranges from January 1, 2023 to June 29, 2023.

DTE5 Hourly





Data Analysis

- 1) DTE 5 is displaying a downward trend in Frequency
- 2) Further assessment is suggested for this issue

The plots of count of DTE 5.csv and average of Frequency(Hz) for Collection Time Day. The data is filtered on Collection Time (DTE 1) Day, which ranges from January 1, 2023 to June 29, 2023.

DTE6 Hourly




Data Analysis


- 1) DTE 5 is displaying a upward trend in Frequency
- 2) Further assessment is suggested for this issue

The plots of count of DTE 6.csv and average of Frequency(Hz) for Collection Time Day. The data is filtered on Collection Time (DTE 1) Day, which ranges from January 1, 2023 to June 29, 2023.


DTE1 Current




DTE5 Current



DTE4 Current



DTE6 Current



Data Analysis

- 1) DTE 1 showed large drop in Current on Feb 10th (possible tap change) and several times in January
- 2) DTE 1 showed Large spike in Current on March 12th
- 3) DTE 4 showed large spike on Jan 21st




Data Analysis

- 1) DTE 1 showed large drop in Current on Feb 10th (possible tap change) and several times in January
- 2) DTE 1 showed Large spike in Current on March 12th

The trends of average of A, average of B and average of C for Collection Time Hour. The data is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023.

DTE4 Current



Data Analysis

- 1) DTE 4 showed large spike on Jan 21st

The trends of average of A (DTE 4), average of B (DTE 4) and average of C (DTE 4) for Collection Time Hour. The data is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023.

DTE5 Current



The trends of average of A (DTE 5), average of B (DTE 5) and average of C (DTE 5) for Collection Time Hour. The data is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023.

DTE6 Current




The trends of average of A (DTE 6), average of B (DTE 6) and average of C (DTE 6) for Collection Time Hour. The data is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023.

Delta Current


(Phase Imbalance)

ATHENA-POWER.COM


DTE1 Delta




DTE5 Delta



DTE4 Delta




DTE6 Delta



Data Analysis

- 1) DTE 1 showing significant Phase Imbalance in February and large Imbalance on March 13th
- 2) DTE 4 and 5 show constant Phase Imbalances throughout the year
- 3) *Absolute Value of additional load shown on top chart. Bottom chart allows for cancellations*




Data Analysis

- 1) DTE 1 showing significant Phase Imbalance in February and large Imbalance on March 13th

The plots of average of abs(A-B-C) and average of A-B -C for Collection Time Hour. The data is filtered on Collection Time Day, which ranges from January 1, 2023 to June 29, 2023. The view is filtered on Collection Time Hour, which includes everything.


DTE4 Delta



Data Analysis

- 1) DTE 4 shows constant Phase Imbalances throughout the year

DTE5 Delta




Data Analysis

- 1) DTE 5 shows constant Phase Imbalances throughout the year

The plots of average of abs(A-B-C) and average of A-B-C for Collection Time Hour. The data is filtered on Collection Time (DTE 1) Day, which ranges from January 1, 2023 to June 29, 2023.

DTE6 Delta



The plots of average of abs(A-B-C) (DTE 6) and average of A-B-C (DTE 6) for Collection Time Hour. The data is filtered on Collection Time (DTE 1) Day, which ranges from January 1, 2023 to June 29, 2023.

Preliminary Findings

ATHENA-POWER.COM

Major Findings from Sensor Readings - 2023

All UFD Sensors provided rich data counts with minimal gaps in data generation and acquisition throughout 2023

Importance Hierarchy:

1) Frequency Changes

- Very abnormal changes trending up and down (DTE 4 & 5)
- This is likely a grid-side issue and not from the customer-side
- Large black-outs have been associated with such drifts in Frequency

2) Large Imbalances of Current

- Several days of large Imbalances with Current on DTE 1 with large spikes in Current
- DTE 5 & 6 constantly had large Phase Imbalances

Additional Suggestions: Being able to read Power Factor would be helpful in further analysis. Voltage monitoring/sensors would be required to do this.

Additional Information



ATHENA-POWER.COM

Pilot Overview

Detroit Edison (DTE) and Athena Power deployed UFD sensors throughout downtown Detroit. The sensors were primarily deployed on Netbanks and Switchgear to monitor and detect faults.

The sensors were custom developed for DTE and were primarily oriented for fault detection. The sensors are three-phase oriented with power harvesting technology and direct DNP3 output. Cellular connectivity (utilizing the Sierra Wireless RV 50) were equipped on each Athena UFD Sensor. Custom Antennas and cables were developed for the netbank asset class to demonstrate strong connectivity and uptime

The majority of the sensors were deployed in 2021 and 2022. The sensor management system from Athena, known as Aegis, was used to manage the sensor. Aegis was also used to manage the data and analyze trends and report the data findings



DTE Deployment Photos

Detroit Edison (DTE) and Athena Power deployed (7) UFD sensors throughout downtown Detroit. Below are photos of the installations that took place in 2021 and Q1 2022




Netbank Installation

Three-phase Current + Neutral was installed on netbanks throughout downtown Detroit. Secondary Power was used to power the unit



Switchgear Installation

Athena sensors were also installed on switchgear at the Detroit Institute of Art. The sensors were utilizing power harvesting technology



Netbank Installation at John R and Broadway

Monitoring Highlights

DTE Pilot Settings

Configure Device DTE1-NB755-Shelby-John-R

Phase A Threshold: 1000
Phase B Threshold: 1000
Phase C Threshold: 1000
Cycles: 2
Fault Timeout(ms): 40000
 Enable Low Threshold
Current A Low: 50
Current B Low: 50
Current C Low: 50
Heartbeat Interval(Min.): 60
Averaging Queue Size: 5
 Capture Waveform on Faults
 Enable Auto Range
Auto Range Days: 3
Auto Range Percent: 200

Configuration	A Phase	B Phase	C Phase
Flood Status	✓	✓	✓
Communication Status	✓	✓	✓
Configuration	1000	1000	1000
Cycles	2		
Fault Timeout(ms)	40000		
Heartbeat Interval(Min.)	60		
Averaging Queue Size	5		
Current A Low (Amps)	50	50	50
Capture Waveform on Faults	<input checked="" type="checkbox"/>		
Auto Range Days	3		
Auto Range Percent	200		

Resolution

- Resolution capture of 1200Hz and 20 samples per cycle
- Scanning/Intervals at every 15min
- Three Phase Current-Only Monitoring

Fault Detection Settings

- High Current threshold set at 1000amps
- 2 Cycles
- Low Current threshold at 50amps

Communications

- 4G Verizon Cellular
- Sierra Wireless RV 50/55 low power radio

Additional Information

- Netbanks powered through secondary power
- Switchgear powered through power-harvesting



Average Device Uptime: **13,686 Hours / 228 Days**